



Cairo University



LEAKAGE DETECTION IN WATER PIPE NETWORKS USING ARTIFICIAL NEURAL NETWORKS TECHNIQUE

By

Eng: Mahmoud Mohamed Abdallah El-Hadidy

A Thesis Submitted to

The Faculty of Engineering at Cairo University

In Partial Fulfillment of

The Requirements for the Degree of

DOCTOR OF PHILOSOPHY

In

IRRIGATION AND HYDRAULICS ENGINEERING

FACULTY OF ENGINEERING, CAIRO UNIVERSITY

GIZA - EGYPT

2018

LEAKAGE DETECTION IN WATER PIPE NETWORKS USING ARTIFICIAL NEURAL NETWORKS TECHNIQUE

By

Eng: Mahmoud Mohamed Abdallah El-Hadidy

A Thesis Submitted to

The Faculty of Engineering at Cairo University

In Partial Fulfillment of

The Requirements for the Degree of

DOCTOR OF PHILOSOPHY

In

IRRIGATION AND HYDRAULICS ENGINEERING

Under The supervision of

Dr. Ahmad Wagdy Abdeldayem

Professor of Hydrology
Irrigation & Hydraulics Dept.
Faculty of Engineering
Cairo University
.....

Dr. Mohamed Gad El-Rab Hafiz

Assistant Professor
Irrigation & Hydraulics Dept.
Faculty of Engineering
Cairo University
.....

FACULTY OF ENGINEERING, CAIRO UNIVERSITY

GIZA - EGYPT

2018

LEAKAGE DETECTION IN WATER PIPE NETWORKS USING ARTIFICIAL NEURAL NETWORKS TECHNIQUE

By

Eng: Mahmoud Mohamed Abdallah El-Hadidy

A Thesis Submitted to
The Faculty of Engineering at Cairo University
In Partial Fulfillment of
The Requirements for the Degree of
DOCTOR OF PHILOSOPHY
In
IRRIGATION AND HYDRAULICS ENGINEERING

Approved by the
Examining Committee

Prof. Ahmad Wagdy Abdeldayem
Prof. of Hydrology, Faculty of Engineering, Cairo University

Thesis Main Advisor

Prof. Amgad Sad El-deen El-ansary
Prof. of Hydraulics, Faculty of Engineering, Cairo University

Internal Examiner

Prof. Aly Nabih El-Bahrawy
Prof. of Hydraulics, Faculty of Engineering, Ain Shams University

External Examiner

FACULTY OF ENGINEERING, CAIRO UNIVERSITY

GIZA - EGYPT

2018

Engineer: Mahmoud Mohamed Abdallah Elhadidy

Date of Birth: 17/1/1977

Nationality: Egyptian

E-mail: jana_elhadidy@yahoo.com

Phone: 01006820888

Address: 474/4 seuz canal authority housing, District 3, Ismailia

Registration Date: 1/3/ 2011

Awarding Date: 2018

Degree: Doctor of Philosophy

Department: Irrigation and Hydraulics Engineering

Supervisors: Prof. Dr. Ahmed Wagdy Abdeldayem

Dr. Mohamed Gad El-Rab Hafiz

Examiners: Prof. Dr. Ahmed Wagdy Abdeldayem (Main Advisor)

Prof. Dr. Amgad Sad El-deen El-ansary (Internal Examiner)

Prof. Dr. Aly Nabih El-Bahrawy (External Examiner)

Faculty of Engineering, Ain Shams University



**Title of Thesis: LEAKAGE DETECTION IN WATER PIPE NETWORKS
USING ARTIFICIAL NEURAL NETWORKS TECHNIQUE**

Key Words: water leakage; water pipe networks; ANN; placement of pressure sensors

Summary:

National water security in Egypt is increasingly threatened by Upper Nile projects, climate-induced impacts, and mismanagement/misuse of the available resources. Leakage from pipe distribution networks may reach alarming values. At situations where every drop counts, it becomes inevitable to arrive at a leakage prediction and early warning system. In this study, a computational approach is followed to detect leakages in water distribution networks using Artificial Neural Networks (ANNs) technique. A multi-layer feed-forward back-propagation artificial neural network using Matlab Neural Network Toolkit is applied. The main objective of this research is to formulate a simple, yet effective leakage detection system (or more) appropriate for water supply networks. Secondary objectives include testing an applicable leakage detection system for Ismailia Water Distribution System (IWDS) to enhance its performance. Also, sensitivity analysis for such networks is applied to choose minimum number of sensors that can perfectly simulate leakage location and discharge in the studied networks. This study presents a generic methodology appropriate for leak detection both in location and magnitude.

A hydraulic model is created for the IWDS and about 1171 leakage scenarios at probable leakage nodes with different discharge ratios (20%, 30%, and 40% of maximum discharge passing through these nodes) are proposed to train ANN to recognize probable leakage locations and discharges corresponding to a wide range of sensor responses (ΔP s). Another 99 leakage scenarios with different discharge ratios (25%, 35%, and 45 % of maximum discharge passing through nodes) are proposed to calibrate the ANN model with post regression test. It's concluded that the ANN model presents a good and reliable alternative for simulating leakage detection for water supply networks. Finally, the study shows that leakage locations detected by the current methodology in 82 % of the cases tested lay within 600m or less from the actual coordinates and about 73% of the cases tested lay within 500m or less.

Acknowledgement

All thanks are for ALLAH the most merciful, the most beneficent for all his bounties.

I would like to express my deepest gratitude and appreciation to **Dr. Ahmed Wagdy**, Professor of Hydrology, Cairo University, for his sincere supervision, guidance, extremely helpful discussions, comprehensive review, valuable suggestions, and advice throughout the course of this work.

I am also deeply grateful for the valuable guidance of **Dr. Mohamed Gad El-rab**, Assistant Professor of Hydraulic and Irrigation, Cairo University for his time, dedication, patient, support, advice, participation, and guidance. He spared no effort or time in helping me to complete this work.

I wish express my deepest thanks to the Examining Committee **Amgad El-ansary**, Professor of Hydraulic and Irrigation, Cairo University, and. **Aly El-Bahrawy**, Professor of Hydraulic and Irrigation, Ain Shams University for their comprehensive advice, and comments that refine this work. I deeply appreciate their helpful response.

My gratitude also extends to the all these people who helped me in the production of this work especially, my friends **Dr. Mostafa Adel**, and **Eng. Mohamed El-Serafy**.

Finally, but no means least, I would like to thank my family (**Mother, wife**) without whom this work would not have been finished. Their endless patience and encouragement is a blessing.

TABLE OF CONTENT

TABLE OF CONTENT	I
LIST OF TABLES.....	IV
LIST OF FIGURES.....	V
LIST OF SYMBOLS.....	VIII
ABSTRACT	IX
CHAPTER 1.....	1
INTRODUCTION	1
1.1 PROBLEM DEFINITION	1
1.2 OBJECTIVES	1
1.3 APPROACH	2
1.4 THESIS OVERVIEW	2
CHAPTER 2.....	4
LITERATURE REVIEW	4
2.1 WATER LOSSES	4
2.2 CAUSES OF PIPE NETWORK LEAKAGE	6
2.3 LEAKAGE DETECTION TECHNIQUES	6
2.3.1 <i>Non acoustic detection techniques</i>	7
2.3.2 <i>Acoustic detection methods</i>	8
2.3.3 <i>Hydraulic leak detection methods</i>	9
2.4 ARTIFICIAL NEURAL NETWORK AN OVERVIEW	11
2.5 MONITORING SENSORS PLACEMENT	17
CHAPTER 3.....	20
METHODOLOGY AND DESCRIPTION OF LEAKAGE DETECTION	
MODELING	20
3.1 METHODOLOGY BACKGROUND.....	20
3.1.1 <i>Compiling background data to build a hydraulic model</i>	21
3.1.2 <i>Specifying enough leakage scenarios</i>	27
3.1.3 <i>Conducting of sensitivity analysis and sensors placement</i>	29
3.1.4 <i>Dividing network area to appropriate subzones</i>	30
3.1.5 <i>Formulating the sensitivity matrices for subzones and identification of the best detector locations</i>	31
3.1.6 <i>Training of artificial neural network (ANN) model</i>	32
3.1.7 <i>Applying (ANN) to detect leakage locations and magnitudes</i>	36
CHAPTER 4.....	39
CASE STUDY	39

4.1 INTRODUCTION	39
4.2 CASE STUDY BACKGROUND	39
4.3 COLLECTING DATA FOR IWPB AND IWTP	43
4.4 DEVELOPMENT OF HYDRAULIC MODEL FOR IWPB	46
4.4.1 Hydraulic model calibration	48
4.4.2 Hydraulic model results for IWPB	49
4.4.3 Modification of hydraulic model of IWPB	51
4.5 FORMULATION OF LEAKAGE SCENARIOS FOR IWPB AND IDENTIFICATION OF BEST SENSORS LOCATION	52
4.6 SUBZONE DIVISIONS AND PROPOSING OF FINAL SENSOR DISTRIBUTIONS FOR IWPB	55
4.7 (ANN) ARTIFICIAL NEURAL NETWORK DEVELOPING MODELS	63
4.7.1 Developing ANN leakage detection model (Ismailia 1) for IWPB	64
4.7.1.1 (Ismailia 1) ANN model robustness determination and calibration...	66
4.7.1.2 Training state	67
4.7.1.3 (Ismailia 1) ANN model regression test	68
4.7.1.4 (Ismailia 1) ANN Post regression test	68
4.7.2 Developing of (Ismailia 2) ANN model for detecting leakage location coordinates (X, Y), and magnitude for IWPB	69
4.7.2.1 Robustness determination and calibration for (Ismailia 2) ANN model	72
4.7.2.2 Training state for (Ismailia 2) ANN model	73
4.7.2.3 ANN regression test for (Ismailia 2) ANN model	73
4.7.2.4 Post regression test for (Ismailia 2) ANN model	73
CHAPTER 5.....	76
RESULTS AND DISCUSSIONS.....	76
5.1 INTRODUCTION	76
5.2 SENSITIVITY OF SENSORS	76
5.3 ELIMINATED SCENARIOS	81
5.4 IDENTIFICATION OF LEAKAGE LOCATIONS AND MAGNITUDES	82
5.4.1 ANN analysis (subzone – magnitude) (Ismailia 1) model for IWPB	82
5.4.1.1 Leakage location for (Ismailia1) model	82
5.4.1.2 Leakage magnitudes evaluation for (Ismailia 1) model	87
5.4.2 Identification of leakage geo-location (coordinates) and magnitudes for IWPB	90
5.4.2.1 Leakage location evaluation for (Ismailia 2) ANN model	90
5.4.2.2 Leakage magnitudes evaluation for (Ismailia 2) ANN model	96
CHAPTER 6.....	97
SUMMARY, CONCLUSIONS, AND RECOMMENDATIONS	97

6.1 INTRODUCTION	97
6.2 SUMMARY	97
6.3 CONCLUSIONS	97
6.4 RECOMMENDATIONS	98
REFERENCES	99
APENDIX A	105
ISMAILIA WATER PIPE NETWORK IWPB HYDRAULIC MODELING ANALYSIS.....	105
APENDIX B	134
LEAKAGE SCENARIOS FOR ISMAILIA WATER PIPE NETWORK IWPB HYDRAULIC MODELING ANALYSIS.....	134

LIST OF TABLES

Table 2-1: IWA standard international water balance and terminology as indicated by Farley and Trow (2003).....	5
Table 3-1: Values of H.W (C) coefficient for different types of pipe material. (Yan et al. (2006)).....	25
Table 3-2: Example of binary sensitivity matrix details.....	30
Table 4-1: Ismailia Water Pipe Network IWPN pipe diameter and lengths	43
Table 4-2: Summary of IWTP treatment trains	45
Table 4-3. Ismailia Water Pipe Network IWPN hydraulic model summary.....	47
Table 4-4: Benchmark nodes for pressure calibration.....	49
Table 4-5: Pressure comparison at some nodes due to leakage scenario at node (junc 61) equal (50 lps) corresponding to operating pump system and not operating pump system to evaluate pump effects	52
Table 4-6: Trials for modeling ANN structure for detecting leakage location (subzone) and magnitude for IWPN and their outputs regression	65
Table 4-7: Summary of (Ismailia 1)ANN leakage detection model (subzone-magnitude) for IWPN.	66
Table 4-8: Trials for modeling ANN structure for detecting leakage location(X, Y coordinates), and magnitude for IWPN and their outputs regression.....	71
Table 4-9: (Ismailia 2) ANN leakage detection model (X,Y coordinates-Magnitude). 72	
Table 5-1: Sensors distance (m) to treatment plant (Coordinated base)	77
Table 5-2: Sensor density for IWPN	81
Table 5-3: Evaluation of (Ismailia 1) ANN model for leakage detection location (subzone) for IWPN.....	84
Table 5-4: Evaluation of (Ismailia 1) ANN model for detecting leakage magnitudes...	88

LIST OF FIGURES

Figure 2-1: Biological neural network inspired from the structure of the brain.....	12
Figure 2-2: Structure of the artificial neural network (ANN)	13
Figure 2-3: Logsigmoid transfer function used in training the ANN	14
Figure 2-4: Tansigmoid transfer function used in training the ANN	15
Figure 2-5: Linear transfer function used in training the ANN	15
Figure 3-1: Methodology plan for leakage detection at pipe network.	21
Figure 3-2: Assembling of hydraulic model and calibration processes.....	26
Figure 3-3: Construction of overall sensitivity matrix and identification of overall sensors locations	28
Figure 3-4: Flowchart for identifying the final sensor placement for leakage detection purposes along the whole network	32
Figure 3-5: Backpropagation feedforward network for leakage detection model with (n) sensors reading and two outputs, which are leakage location and magnitude	33
Figure 3-6: Post regression test flowchart	38
Figure 4-1: Ismailia town layout	40
Figure 4-2: Ismailia City containing main roads and specifying pipe network distribution.....	42
Figure 4-3: IWPN nodes distribution, and base demands allocation	43
Figure 4-4: Ismailia Water Pipe Network layout.....	44
Figure 4-5: Ismailia Water Treatment Plant (IWTP) treatment trains, and main pipes .	45
Figure 4-6: Ismailia Water Pipe Network IWPN nodes elevations.....	47
Figure 4-7: Benchmark node distribution for pressure calibration.....	48
Figure 4-8: Ismailia Water Pipe Network IWPN pressure distributions.	49
Figure 4-9: Flow direction and magnitude at IWPN	50
Figure 4-10: IWPN velocity distributions.	50
Figure 4-11: Leakage location, and monitoring nodes to evaluate pump effect in IWPN	52
Figure 4-12: Pressure differences (ΔP)(m) of all nodes due to leakage scenarios at node 463 indicated by ✱. a) refers to 20% leakage, b) refers to 30% leakage, and c) refers to 40% leakage	54
Figure 4-13: Most sensitive nodes due to overall sensitivity matrix and proposed sensors.	55
Figure 4-14: IWPN divided sub-zones	56
Figure 4-15: Subzones demands compared with 135.56 lps (Equation (3-10)).....	57

Figure 4-16: Sensitivity nodes and proposed sensors for subzone 1. The figure confirms that no need for additional sensor.....	58
Figure 4-17: From a to d show the most sensitive nodes for zones 2, 3,4, and 5 respectively, which don't need additional sensors	59
Figure 4-18: From a to d show the most sensitive nodes for zones 9, 12,13, and 14 respectively, which require additional detecting sensors	62
Figure 4-19: Final distribution of sensitive sensors locations for Ismailia Water Pipe Network IWPNN	63
Figure 4-20: Schematic of (Ismailia 1) ANN leakage detection model (subzone – magnitude) for IWPNN	64
Figure 4-21: Architecture of (Ismailia 1) ANN leakage detection model (subzone-magnitude) for IWPNN	66
Figure 4-22: Performance of ANN of leakage detection model (subzone –magnitude).67	
Figure 4-23: Training state of ANN of leakage detection model (subzone –magnitude).	67
Figure 4-24:Overall regression test of (Ismailia 1) ANN leakage detection model (subzone –magnitude) for training, validating, testing,and overall parameters	68
Figure 4-25: Overall post regression test for leakage detection (subzone-magnitude) model.	69
Figure 4-26: Schematic of (Ismailia 2)ANN model of leakage (coordinates –magnitude) model	70
Figure 4-27: Architecture of (Ismailia 2) ANN leakage detectionmodel (X,Y coordinates-magnitude)	71
Figure 4-28: Performance of (Ismailia 2) ANN of leakage detection (X, Y coordinates-magnitude) model for IWPNN.	72
Figure 4-29: Training state of (Ismailia 2) ANN model for detecting leakage (X, Y coordinates), and magnitude for IWPNN	73
Figure 4-30: From (a) to (c) indicate regression for leakage detection (Ismailia 2) ANN model for (X, Y coordinates), and leakage magnitude respectively.	74
Figure 4-31: From (a) to (c) (ISMAILIA 2) ANN model post regression test for a) X coordinate, b) Y coordinate and c) leakage magnitude for IWPNN leakage detection model	75
Figure 5-1: Final sensor distributions among different subzone of IWPNN.....	76
Figure 5-2: From a) to c) indicate sensors'sensitivity to leakage incidents for sensors S1,S2, and S3 respectively, (% of leakage scenarios within a specific subzone that are detectable by each specific sensor ie. $\Delta P \geq .1$ m at the specific sensor)	78
Figure 5-3: Discharge of eliminated scenarios at different subzones.....	82
Figure 5-4: Evaluation of (Ismailia 1) ANN model for detecting leakage location (subzone)for IWPNN.....	87
Figure 5-5: Evaluation of (Ismailia 1) ANN model for detecting leakage magnitude for IWPNN	89

Figure 5-6: (a) Shows real and estimated location for leakage location identification by using (Ismailia 2) ANN model at IWPN (b) visualizes the clear distance between real and estimated location through Google Earth application.....	91
Figure 5-7: From (a) to (b) simulated and real leakage location comparison and plotting at Google Earth application.	92
Figure 5-8: From (a) to (d) clear distance between real leakage node and estimated leakage node for two scenarios, (a),(b). Clear distance between real and estimated nodes are 96 m, 207 m respectively.	93
Figure 5-9: From (a) to (d) clear distance between real leakage node and estimated leakage node for two scenarios, (a),(b), which are 481 m, and 415 m respectively.	94
Figure 5-10: Differences between real and estimated location for (Ismailia 2) ANN model (X, Y coordinates, and leakage magnitudes).....	95
Figure 5-11: Leakage magnitudes differences between estimated and real leakage discharges for (Ismailia 2) ANN model.	96

LIST OF SYMBOLS

AC	Asbestos Cement
ANN	Artificial Neural Network
AWWA	American Water Work Association
DI	Ductile Iron
DMA	District Metering Area
FCV	Flow Control Valve
FFNN	Feed forward neural network
GPV	General Purpose Valve
IWA	International Water Association
IWPN	Ismailia Water Pipe Network
IWTP	Ismailia Water Treatment Plant
PBV	Pressure Breaker Valve
PRV	Pressure Reducing Valve
PSV	Pressure Sustaining Valve
SCA	Suez Canal Authority
TCV	Throttle Control Valve
UPVC	Unplasticized Polyvinyl Chloride
WPS	Water Distribution System
WTP	Water Treatment Plant
ΔP	Pressure difference (sensor response)

ABSTRACT

Leakage Detection in Water Pipe Networks Using Artificial Neural Networks Technique

National water security in Egypt is increasingly threatened by Upper Nile projects, climate-induced impacts, and mismanagement/misuse of the available resources. Leakage from pipe distribution networks may reach alarming values (nearly one third of the produced water is vulnerable to losses through undetected leakage). At situations where every drop counts, it becomes inevitable to arrive at a leakage prediction and early warning system. In earlier attempts, the literature for leakage detection location and discharge acknowledge high levels of uncertainties, and most of them do not incorporate the uncertainties related to the different water distribution system parameters in their algorithms. In this study, a computational approach is followed to detect leakages in water distribution networks using Artificial Neural Networks (ANNs) technique. ANNs are robust and can be used to model complex linear and non-linear systems without making implicit assumptions as is the case in most traditional statistical approaches. A multi-layer feed-forward back-propagation artificial neural network using Matlab Neural Network Toolkit is applied. The main objective of this research is to formulate a simple, yet effective leakage detection system (or more) appropriate for water supply networks. Secondary objectives include testing an applicable leakage detection system for Ismailia Water Distribution System (IWDS) to enhance its performance. Also, sensitivity analysis for such networks is applied to choose minimum number of sensors that can perfectly simulate leakage location and discharge in the studied networks. This study presents a generic methodology appropriate for leak detection both in location and magnitude.

A hydraulic model is created for the (IWDS) and about 1171 leakage scenarios at probable leakage nodes with different discharge ratios (20%, 30%, and 40% of maximum discharge passing through these nodes) are proposed to train ANN to recognize probable leakage locations and discharges corresponding to a wide range of sensor responses (ΔP s). Another 99 leakage scenarios with different discharge ratios (25%, 35%, and 45 % of maximum discharge passing through nodes) are proposed to calibrate the ANN model with post regression test. It's concluded that the ANN model presents a good and reliable alternative for simulating leakage detection for water supply networks. Finally, the study shows that leakage locations detected by the current methodology in 82 % of the cases tested lay within 600m or less from the actual coordinates and about 73% of the cases tested lay within 500m or less.

CHAPTER 1

INTRODUCTION

Water is one of our most precious natural resources. With the growing demands, limited resources, climate variability and uncertainties about feature of Nile flow; water conservation in Egypt becomes a top priority. Leakage is one of the primary reason for losing treated water; losses due to leakage in many countries has been estimated as third of the total pumped water in distribution networks **Liemberger et al. (2007)**. Leakage impacts the coupled natural-human system from different perspectives, including (i) serious financial damage (e.g. damage of infrastructure, losing of treated water), (ii) environmental hazards (e.g. entry of pollutants inside pipes, pooling water for long time) (iii) socially (e.g. treated water shortage, especially in the development countries). Leakage detection procedures are the main mitigation process, which can detect leakage early as soon as possible to minimize water losses due to leakage at pipe networks. Therefore, it is preferable that the appearance of a leak in a pipe be identified and located as soon as possible.

It is of interest to develop models which can simulate and detect leakage occurred at pipe networks. There are several types of leakage detection systems appropriate to water distribution pipe networks. Evaluation of such ways depends on the response time to leakage. Using hydraulic characteristic properties for such pipe network systems to detect leakage, has a good and reliable results in detecting leakage. Artificial Neural Network (ANN) technique has promising results in detecting leakage at pipe networks, which can solve non-linear and complex problems. A framework application for detecting leakage at pipe networks using ANN model, hydraulic model simulation by EPANET, and applying simple binary-based optimization analysis to identify the best pressure sensors locations have been developed. The framework is successfully applied for Ismailia water pipe networks IWPEN as an actual application.

1.1 Problem Definition

The response of such model for detection leakage at pipe networks depends on simulating the equations of each operation at the system. Pipe networks have complex operation equations, which are non-linear and have multivariable function, which are very difficult to be simulated. Addition to the lack of providing communities with treated water especially at developing countries. This work has concerned with developing a frame work for pipe networks leakage detection procedures and applying it to Ismailia Water Pipe Network IWPEN.

1.2 Objectives

The objectives of this study can be summarized as follows:

The main objective is to formulate a simple, yet effective leakage detection system framework appropriate for water pipe networks. This is achieved by developing a calibrated hydraulic simulation model, suggesting a technique to identify the minimum numbers of pressure sensors, and their distribution needed to monitor large water pipe networks, and detect any probable significant leakage in the network. Finally, using the